In addition, two barriers that are 16 feet high and 100 feet in length will be constructed approximately 10 feet to the east of the two inverter skids in Area 5. The Facility Substation transformer noise barrier will be constructed of materials that have a minimum surface weight of 4 pounds per square foot (lb/ft² or psf). Examples of materials that would meet these requirements include poured concrete, concrete panels, concrete masonry blocks, including "acoustical" block, or metal panels, including "acoustical" panels. The two noise barriers in Area 5 will be constructed of a product similar to Acustifence from Acustiblok and has a sound transmission class (STC) rating of 28. An Example of this noise barrier can be found in Attachment 5. The locations of the noise barriers are shown in Figures 25 and 27. Results in Attachment 1, Table A-2 and Table A-4, show mitigated sound levels are at or below 45 dBA (including the tonal penalty) at all receptors, meeting the §94-c limit for participating and nonparticipating residential receptors. In addition, the Facility Substation transformer is at or below 40 dBA (including the tonal penalty) at the closest home. All property line sound levels are at or below 43 dBA, well below the ORES limit of 55 dBA and the Town of Somerset's limit of 50 dBA. Results also show compliance with the Town of Somerset's Solar Law of 45 dBA at a residential structure.

In addition to the comprehensive acoustic modeling results tables presented in Attachment 1, summarized results are given in Table 25 through Table 28. Table 25 and Table 26 present the lowest and highest sound levels received during full operations and Facility Substation-only operations without and with the implementation of noise mitigation measures, respectively. Results are given for three receptor types in Table 25 and Table 26; at the property line, at the one receptor participating in the Facility, which is a non-residential use (i.e., museum), and at non-participating receptors. Table 27 and Table 28 show the number of non-participating NSAs that are expected to experience received sound levels of 35 dBA or more during full operations and Facility Substation-only operations without and with the implementation of noise mitigation measures, respectively. The location of all operating equipment included in the noise model can be found in Attachment 3.



Table 25: Summary of Modeled Unmitigated Operational Results, dBA

	Full Operations				Substation-Only			
Receptor Type	Min		Max		Min		Max	
	W/o Penalty	With Penalty	W/o Penalty	With Penalty	W/o Penalty	With Penalty	W/o Penalty	With Penalty
Property Line	27	27 ¹	59	59 ¹	19	19 ¹	41	41 ¹
Participating (Non- resident/mus- eum)	43	48	43	48	40	45	40	45
Non- participating (Residential)	12	17	43	48	11	16	42	47

¹Tonal penalty does not apply to property line sound levels

dBA – A-weighted decibels

Table 26: Summary of Modeled Mitigated Operational Results, dBA

	Full Operations				Substation-Only			
Receptor Type	Min		Max		Min		Max	
Receptor Type	Without Penalty	With Penalty	Without Penalty	With Penalty	Without Penalty	With Penalty	Without Penalty	With Penalty
Property Line	26	26¹	43	43 ¹	19	19 ¹	35	35 ¹
Participating (Non-residential/museum)	42	46	42	46	39	44	39	44
Non-participating (Residential)	7	12	40	45	0	5	35	40

¹Tonal penalty does not apply to property line sound levels

dBA – A-weighted decibels

Table 27: Summary of Unmitigated Sound Pressure Levels (LP) above 35 dBA

	Number of Non-participating Sensitive Receptors						
L _P – Maximum L _{8H} (dBA)	Full Ope	rations	Substation-Only				
	Without Tonal Penalty	With Tonal Penalty	Without Tonal Penalty	With Tonal Penalty			
35	1	3	0	3			
36	0	4	1	5			
37	0 5		0	5			
38	1	8	0	2			



	Number of Non-participating Sensitive Receptors						
L _P – Maximum L _{8H}	Full Ope	rations	Substation-Only				
(dBA)	Without Tonal Penalty	With Tonal Penalty	Without Tonal Penalty	With Tonal Penalty			
39	0	2	0	0			
40	0	1	0	0			
41	0	0	0	1			
42	0	0	1	0			
43	1	1	0	0			
44	0	0	0	0			
45	0	0	0	0			
46	46 0		0	0			
47	0	0	0	1			
48	0	1	0	0			
49	0	0	0	0			

dBA – A-weighted decibels; L_{8H} – 8-hour average

Table 28: Summary of Mitigated Sound Pressure Levels (LP) above 35 dBA

	Number of Non-participating Sensitive Receptors							
L _P – Maximum L _{8H}	Full	Operations	Substation-Only					
(dBA)	Without Tonal With Tonal Penalty Penalty Penalty			With Tonal Penalty				
35	0	2	1		3			
36	1	10	0		4			
37	0 2		0		1			
38	0	5	0		0			
39	0	1	0		1			
40	1	0	0		1			
41	0	1	()	0			
42	0	0	0		0			
43	0	0	0		0			
44	0	0	0		0			
45	0	1	0		0			

dBA – A-weighted decibels; L_{8H} – 8-hour average





















